


NOTES


1. TOTAL LLF FOR THIS ANALYSIS IS .75
2. TYPICAL 30'X30'X9' AREA
3. REFLECTANCES= 80/50/20
4. LLD .95/ LDD .90 / BF .88
5. WATTS PER SQ. FT.= .77
6. 2AV= 10' X 8' CENTERS
7. HORIZONTAL READINGS AT 2.5' AFF.

STATISTICS


| Description | Avg | Max | Min | Max/Min | Avg/Min |
|-------------|-------|-------|-------|---------|---------|
| North Wall | 22 fc | 37 fc | 18 fc | 2.1:1 | 1.2:1 |
| West Wall | 25 fc | 30 fc | 22 fc | 1.4:1 | 1.1:1 |
| Workplane | 34 fc | 43 fc | 19 fc | 2.3:1 | 1.8:1 |

LUMINAIRE SCHEDULE


| Symbol | Qty | Catalog Number | Description | Lumens | LLF |
|---|-----|----------------|--|--------|------|
|  | 12 | 2AV G 2 32 MDR | 2X4 AVante, recessed, 2 lamp T8 32 watt, Metal Diffuser w/ Round perforations backed w/ acrylic overlay. | 2850 | 0.75 |



Plan View
Scale 1" = 7'



VERTICALS,NORTH WALL
Scale 1" = 7'



VERTICALS,WEST WALL
Scale 1" = 7'