



SEQUENCE OF OPERATION:

- LIGHTS**
 - ALL LIGHTS ARE DIMMABLE
- OCCUPANCY**
 - LIGHTS MUST BE TURNED ON MANUALLY
 - LIGHTS AUTOMATICALLY TURN OFF WHEN ROOM BECOMES VACANT
- DAYLIGHT**
 - SMOOTH CONTINUOUS DIMMING
 - DAYLIGHT ZONE DEFINED BY ROWS
 - NOT REQUIRED FOR AREAS WITHOUT WINDOWS OR THAT HAVE LOADS <150W IN SIDELIGHT ZONES
- MANUAL**
 - ON/OFF
- ADDITIONAL OPTIONS:**
 - SURFACE OR RECESSED MOUNT SENSORS ALSO AVAILABLE
 - FOR EMERGENCY LIGHTING CONTROL ADD A PP16 SHUNT PACK.

DIAGRAM LEGEND	
	CLASS 2 LOW VOLTAGE
	LINE VOLTAGE WIRES
	0-10VDC WIRES
	LINE FEED

BILL OF MATERIAL		
QTY	PRODUCT #	DESCRIPTION
1	PP20	RELAY MODULE
1	SPODM SA	MANUAL ON/AUTO OFF WALL POD
1	CM PDT 9	DUAL TECHNOLOGY OCCUPANCY SENSOR
OPTIONS		
1	CM ADC	AUTOMATIC DIMMING CONTROL PHOTOCELL

SUPPORTS THE FOLLOWING REQUIREMENTS:

- FULL AUTO-OFF VIA OCCUPANCY SENSOR (C405.2.1.1)
- LOCAL SWITCH (C405.2.2.3)
- LIGHTING REDUCTION (C405.2.2.2)