

SEQUENCE OF OPERATION:

LIGHTS

- LIGHT(S) ON/OFF SWITCHING ONLY
- MULTI-LEVEL (DIMMING) REQUIRED IF >100sqft AND > 1 FIXTURE

OCCUPANCY




- LIGHTS AUTOMATICALLY TURN ON TO FULL WHEN OCCUPANT ENTERS (RECOMMENDED) OR CAN BE CONFIGURED TO MANUAL ON
- LIGHTS AUTOMATICALLY TURN OFF WHEN SPACE BECOMES VACANT

MANUAL

- MASTER ON/OFF CONTROL OF ENTIRE SPACE

ADDITIONAL OPTIONS:

- SURFACE OR RECESSED MOUNT SENSORS ALSO AVAILABLE
- SPACE CAN BE CONNECTED TO NLIGHT BACKBONE TO ENABLE NET-WORK CONTROL OR ADR (AUTOMATIC DEMAND RESPONSE)
- FOR EMERGENCY LIGHTING CONTROL ADD A NPP16 D ER PACK.

DIAGRAM LEGEND	
	CAT-5e CABLE
	LINE VOLTAGE WIRES
	LINE FEED

BILL OF MATERIAL		
QTY	PRODUCT #	DESCRIPTION
1	nPP16	RELAY PACK
1	nWSX PDT LV	DUAL TECHNOLOGY OCCUPANCY WALL SWITCH

SUPPORTS THE FOLLOWING REQUIREMENTS:

 FULL AUTO-OFF VIA OCCUPANCY SENSOR (SECTION 130.1c)

 LOCAL SWITCH (SECTION 130.1a)

 AUTOMATIC DEMAND RESPONSE (ADR) READY (SECTION 130.1e)