
ASHRAE DESIGN GUIDE 90.1-2016

WIRELESS STAIRWELL WITH NLIGHT AIR ENABLED FIXTURES





SEQUENCE OF OPERATION:

- ALL LIGHTS ARE DIMMABLE
- MAXIMUM LEVEL CAN BE LIMITED TO 80%

OCCUPANCY

- LIGHTS AUTOMATICALLY GO TO FULL BRIGHT WHEN OCCUPIED
- LIGHTS AUTOMATICALLY DROP TO 50% (OR OTHER DIM SETTING) WHEN SPACE BECOMES VACANT


MANUAL

- NOT REQUIRED

ADDITIONAL OPTIONS:

- SURFACE OR RECESSED MOUNT SENSORS ALSO AVAILABLE
- SPACE / ZONE CAN BE CONNECTED TO NLIGHT BACKBONE TO ENABLE NETWORK CONTROL OR ADR (AUTOMATIC DEMAND RESPONSE)
- HVAC CONTROL AVAILABLE THROUGH SYSTEM-WIDE BACNET INTERFACE OPTION ON ECLYPSE CONTROLLER.

(1) Fixtures assumed to be battery backup



| BILL OF MATERIAL | | |
|------------------|----------|---|
| QTY | PRODUCT# | DESCRIPTION |
| 1 | SEE NOTE | nLIGHT AIR ENABLED FIXTURES |
| 1 | SEE NOTE | nLIGHT AIR ENABLED FIXTURES (BATTERY BACKUP) |

SUPPORTS THE FOLLOWING REQUIREMENTS:



