

SEQUENCE OF OPERATION:


LIGHTS
 - ALL LIGHTS ARE DIMMABLE
 - MAXIMUM LEVEL CAN BE TASK TUNED TO ANY PERCENTAGE VIA PROGRAMMING

OCCUPANCY
 - PARTIAL-ON OCCUPANCY SENSORS AUTOMATICALLY ACTIVATE BETWEEN 50-70% OF CONTROLLED LIGHTING POWER OR FIXTURES MUST BE TURNED ON MANUALLY
 - FIXTURES AUTOMATICALLY TURN OFF WHEN ROOM BECOMES VACAN

DAYLIGHT
 -NOT REQUIRED IF ROOM HAS <24 FT2. OF GLAZING OR LIGHTING LOAD < 120W IN THE SKYLIT AND THE SIDELIT DAYLIT ZONE
 - SMOOTH CONTINUOUS DIMMING
 - DAYLIGHT ZONES DEFINED BY RELAY PACKS MANUAL

- ON/OFF & RAISE/LOWER CONTROL OF LIGHTS

ADDITIONAL OPTIONS:
 - ROOM CAN BE CONNECTED TO NLIGHT BACKBONE TO ENABLE NETWORK CONTROL, TIME SCHEDULES AND AUTOMATED DEMAND RESPONSE (OPENADR 2.0A)
 - HVAC CONTROL AVAILABLE THROUGH SYSTEM-WIDE BACNET® INTERFACE OPTION ON THE ECLYPSE CONTROLLER OR THROUGH OCCUPANCY SENSOR AUXILIARY RELAY (AR) CONTACT OPTION
 - WIRELESS FIXTURE EMBEDDED CONTROL AND OCCUPANCY/DAYLIGHTING SENSOR OPTIONS AVAILABLE,
 PLEASE SEE THE FIXTURE SPECIFICATION SHEET



BILL OF MATERIAL

QTY	PRODUCT #	DESCRIPTION
18	SEE NOTE	NLIGHT AIR ENABLED FIXTURE
6	SEE NOTE	NLIGHT AIR ENABLED FIXTURE with EM OPTION
2	iPODB 2P G2	2 POLE ON/OFF WALL POD

SUPPORTS THE FOLLOWING REQUIREMENTS:

- FULL AUTO-OFF VIA OCCUPANCY SENSOR (SECTION 130.1c)
- AREA CONTROL (SECTION 130.1a)
- MULTI-LEVEL/ DIMMING CONTROL (SECTION 130.1b)
- AUTOMATIC DEMAND RESPONSE (ADR) READY (SECTION 130.1e)
- LESS THAN 120W PRIMARY DAYLIGHT ZONE DO NOT REQUIRE DAYLIGHT HARVESTING (SECTION 130.1d)

Note: Contact your local lighting agent for more information on nLight enabled fixtures