


WSEC 2015 DESIGN GUIDE

WIRELESS PRIVATE OFFICE < 250sqft WITH 0-10V DIMMING FIXTURES & WINDOW(S)



SEQUENCE OF OPERATION:

LIGHTS

- ALL LIGHTS ARE DIMMABLE
- ADJUSTABLE HIGH/LOW TRIM

OCCUPANCY

- FIXTURES MUST BE TURNED ON MANUALLY (OR OPTIONALLY CAN BE CONFIGURED TO COME ON AUTOMATICALLY TO 50%)
- FIXTURES AND RECEPTACLES AUTOMATICALLY TURN OFF WHEN ROOM BECOMES VACANT

DAYLIGHT

- NOT REQUIRED FOR OFFICES WITHOUT WINDOWS OR THAT HAVE LOADS <150W IN SIDELIGHT ZONES

MANUAL

- ON/OFF & RAISE/LOWER CONTROL OF LIGHTS

ADDITIONAL OPTIONS:

- ROOM CAN BE CONNECTED TO nLIGHT BACKBONE TO ENABLE NET-WORK CONTROL OR TIME SCHEDULES (C405.2.2.1)
- HVAC CONTROL AVAILABLE THROUGH SYSTEM-WIDE BACNET® INTERFACE OPTION ON THE ECLYPSE CONTROLLER OR THROUGH OCCUPANCY SENSOR AUXILIARY RELAY (AR) CONTACT OPTION

DIAGRAM LEGEND	
	LOW VOLTAGE WIRES
	LINE VOLTAGE WIRES
	0-10VDC WIRES
	LINE FEED

BILL OF MATERIAL		
QTY	PRODUCT #	DESCRIPTION
2	rPP20 D 24V G2	RELAY PACK WITH 0-10V DIMMING OUTPUT
1	rPP20 24V G2	PLUG LOAD RELAY PACK
1	rPODB DX G2	ON/OFF & RAISE/LOWER WALL POD
2	rCMS PDT 9 G2	OCCUPANCY AND DAYLIGHT SENSOR

SUPPORTS THE FOLLOWING REQUIREMENTS:

- FULL AUTO-OFF VIA OCCUPANCY SENSOR (C405.2.1.1)
- LOCAL SWITCH (C405.2.3)
- LIGHTING REDUCTION (C405.2.2.2)
- PLUG LOAD CONTROL (C405.10)