

**SEQUENCE OF OPERATION:**

**LIGHTS**

- ALL FIXTURES ARE DIMMABLE
- OPTIONAL AUTOMATIC LUMEN COMPENSATION
- ADJUSTABLE HIGH/LOW TRIM

**OCCUPANCY CONTROL:**



- FIXTURES AUTOMATICALLY GO TO FULL BRIGHT WHEN OCCUPIED OR OPTIONALLY CAN BE CONFIGURED TO A LOW DIM SETTING
- FIXTURES AUTOMATICALLY TURN OFF WHEN SPACE BECOMES VACANT

**MANUAL CONTROL:**

- ON/OFF & RAISE/LOWER CONTROL OF FIXTURES




**ADDITIONAL OPTIONS:**

- SPACE/ZONE CAN BE CONNECTED TO nLIGHT BACKBONE TO ENABLE NETWORK CONTROL OR TIME SCHEDULES (C405.2.2.1)
- HVAC CONTROL AVAILABLE THROUGH SYSTEM-WIDE BACNET® INTERFACE OPTION ON THE ECLYPSE CONTROLLER OR THROUGH OCCUPANCY SENSOR AUXILIARY RELAY (AR) CONTACT OPTION

DIAGRAM LEGEND	
	LINE VOLTAGE WIRES
	LINE FEED

BILL OF MATERIAL		
QTY	PRODUCT #	DESCRIPTION
6	rPP20 D 24V G2	RELAY PACK WITH 0-10V DIMMING OUT PUT
6	rPP20 D 24V ER G2	EMERGENCY RELAY PACK WITH 0-10V DIMMING OUT PUT
3	rPODB 2P G2	2 POLE ON/OFF WALL POD
12	rCMS 6 G2	OCCUPANCY SENSOR

**SUPPORTS THE FOLLOWING REQUIREMENTS:**

-  FULL AUTO-ON OR OFF VIA OCCUPANCY SENSOR (C405.2.1.1.2) (C405.2.1.1.1)
-  LOCAL SWITCH (C405.2.3)
-  DAYLIGHT RESPONSIVE CONTROLS (C405.2.4)

**Note: Contact your local lighting agent for more information on nLight enabled fixtures. nLight enabled fixtures provide Luminaire Level Lighting Controls (LLLC), as specified in the WSEC CODE.**