



## IMPORTANT SAFETY RECALL TO REPAIR LBL4W LED

## Dear Agent:

Lithonia Lighting, a division of Acuity Brands Lighting, Inc., has received reports of the lens used on the LBL4W LED fixture (4-foot wide housing) manufactured between February 2016 and March 201 detaching from the fixture and becoming loose or falling. No injuries have been reported.

Lithonia Lighting has determined that the lenses became loose or fell because the lens was not made to the specified dimensions. This prevented some lenses from being secured in the fixture.

Lithonia Lighting is conducting this voluntary recall in cooperation with the U.S. Consumer Product Safety Commission. Only the LBL4W LED fixture is included in the recall.

Please visit <u>www.lithonia.com</u> to order your free placement lens. If you are unable to place your order via the website or need additional assistance, please contact Lithonia Lighting at 888-876-4181, to make arrangements for Lithonia Lighting to ship the free replacement lens.

If you have any questions concerning this letter, please contact Lithonia Lighting at 888-876-4181. Thank you for your assistance and we apologize for the inconvenience.

Regards,

Lithonia Lighting a division of Acuity Brands Lighting, Inc.

May 25, 2017