


IECC 2015 DESIGN GUIDE
PUBLIC RESTROOM WITH WALL OCCUPANCY SWITCH




SEQUENCE OF OPERATION:

LIGHTS
- ALL LIGHTS ARE SWITCHING
- ALL FIXTURES ARE CONTROLLED TOGETHER (PER ROOM)

OCCUPANCY
- LIGHTS AUTOMATICALLY TURN ON WHEN OCCUPANT ENTERS
- LIGHTS AUTOMATICALLY TURN OFF WHEN ROOM BECOMES VACANT

MANUAL
- MASTER ON/OFF

ADDITIONAL OPTIONS:
- SURFACE OR RECESSED MOUNT SENSORS ALSO AVAILABLE
- FOR EMERGENCY LIGHTING CONTROL ADD A PP16 SHUNT PACK.



BILL OF MATERIAL (per room)

| QTY | PRODUCT # | DESCRIPTION |
|-----|-----------|---------------------------------------|
| 1 | WSX PDT | DUAL TECHNOLOGY WALL OCCUPANCY SWITCH |

SUPPORTS THE FOLLOWING REQUIREMENTS:

✓ FULL AUTO-OFF VIA OCCUPANCY SENSOR (C405.2.1.1)

✓ LOCAL SWITCH (C405.2.2.3)