


IECC 2015 DESIGN GUIDE

OPEN OFFICE WITH WIRELESS OCCUPANCY CONTROL (A/B SWITCHING)
 SENSOR SWITCH WR SERIES



SENSOR SWITCH



SEQUENCE OF OPERATION:

LIGHTS

- ALL LIGHTS ARE SWITCHING
- EACH LOAD CONTROLLED INDEPENDENTLY

OCCUPANCY

- LOAD (B) MUST BE TURNED ON MANUALLY
- LIGHTS AUTOMATICALLY TURN OFF WHEN ROOM BECOMES VACANT

MANUAL

- MASTER ON/OFF FOR EACH LOAD

*LINE VOLTAGE WIRES NOT SHOWN.

DIAGRAM LEGEND	
	LINE FEED

BILL OF MATERIAL		
QTY	PRODUCT #	DESCRIPTION
1	SPODMR WR SA	WIRELESS MANUAL ON/AUTO OFF WALL POD
1	SPODMR WR	WIRELESS ON/OFF WALL POD
4	CM PDT 9 WR	WIRELESS DUAL TECHNOLOGY OCCUPANCY SENSOR

SUPPORTS THE FOLLOWING REQUIREMENTS:

- FULL AUTO-OFF VIA OCCUPANCY SENSOR (C405.2.1.1)
- LOCAL SWITCH (C405.2.2.3)
- LIGHTING REDUCTION (C405.2.2.2)